

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！

ATTESTATION OF CONFORMITY

Issued to: Xiamen SET Electronics Co., Ltd.
No. 8067 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an,
361101 Xiamen Fujian, China

For the product: Surge Protective Device

Trade name: SET or SETfuse or SETsafe

Type/Model: SM08B230N203

Ratings: Test class I/Type 1 and Test class II / Type 2; I_{SCCR}: 3 kA; IP20;
U_c: 320 V~; I_{imp}: 8 kA; I_n: 20 kA; I_{max}: 40 kA; U_p: 2,0 kV

Manufactured by: Xiamen SET Electronics Co., Ltd.
No. 8067 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an,
361101 Xiamen Fujian, China

Requirements: EN 61643-11:2012+A11:2018

This Attestation is granted on account of an examination by DEKRA Shanghai, the results of which are laid down in a confidential file no. 6113693.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 21 October 2022

Number: 6113693.01AOC

DEKRA Certification B.V.

Kate Xu
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

