

认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件：sales@SETfuse.com。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！



Ref. Certif. No.

HU-004988

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device (SPD)

Name and address of the applicant

Xiamen Set Electronics Co., Ltd.
No.8067, Xiang'an Xi Road, Xiamen Torch High-Tech Industrial
Develop- ment Zone, Xiang'an Industry District Xiamen Fujian
P.R. China

Name and address of the manufacturer

Xiamen Set Electronics Co., Ltd.
No.8067, Xiang'an Xi Road, Xiamen Torch High-Tech Industrial
Develop- ment Zone, Xiang'an Industry District Xiamen Fujian
P.R. China

Name and address of the factory

Xiamen Set Electronics Co., Ltd.
No.8001, Xiang'an Xi Road, Xiamen Torch High-Tech Industrial
Development Zone, Xiang'an Industry District, Xiamen,
Fujian
P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uc: 1)2)3)4): 320Vac; 5)6): 275Vac;
Class II + Class III, In: 5 kA, Imax: 10 kA, Uoc: 10 kV,
Up: 1)2): 1.5 kV(L to N), 1.8 kV(L to PE, N to PE);
3)4)5)6): 1.5 kV
1)2)3)4): IP66, 5)6): IP67;
-40°C ~+85°C

Trademark / Brand (if any)

SET, SETsafe, SETfuse

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) SD05K277AMT, AP55277G;
2) SD05K277AM, AP3P277G;
3) SD05K277LMT, AP55277L;
4) SD05K277LM, AP3P277L;
5) SD05K277LMT-D, AP55277LN;
6) SD05K277LM-D, AP3P277LN

Additional Information (if necessary may also be
reported on page 2)

N/A

A sample of the product was tested and found
to be in conformity with

IEC 61643-11:2011
See Test Report for National Differences

As shown in the Test Report Ref. No. which
forms part of this Certificate

CN242CJ6 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-06-14

Signature:

Wencai Zhang
Wencai Zhang

30/06/2024 15:45:03 30-22-07-466-81x